

EntityName	StationLocalCode	SamplePurpose	SampleLabCode	SampleDate	2,4 D	Atrazine	1,2-dichloroethane	Acrylamide	Aluminium	Ammonium	Antimony
Units					µg/l	µg/l	µg/l	µg/l	µg/l	mg/l	µg/l
2014 DW Regs Limit (MAC)					0.1	0.1	0.3	0.1	200	0.3	5
Ballinakill 1 PWS	7	Drinking Water - Audit Monitoring - Public	14340960	12/08/2014	<0.005	<0.005	<0.5	<0.01	<10	<0.03	-
Clonaslee PWS	27	Drinking Water - Audit Monitoring - Public	14340957	12/08/2014	<0.005	<0.005	<0.5	<0.01	28	<0.03	-
Durrow 1 PWS	18	Drinking Water - Audit Monitoring - Public	14340962	12/08/2014	<0.005	<0.005	<0.5	<0.01	<10	<0.03	-
Rosenallis PWS	16	Drinking Water - Audit Monitoring - Public	14340956	12/08/2014	<0.005	<0.005	<0.5	<0.01	<10	<0.03	-
Abbeyleix 2 PWS	49	Drinking Water - Audit Monitoring - Public	14340959	12/08/2014	<0.005	<0.005	<0.5	<0.01	<10	<0.03	-
Abbeyleix 1 PWS	35	Drinking Water - Audit Monitoring - Public	14340958	12/08/2014	<0.005	<0.005	<0.5	<0.01	<10	<0.03	-
Ballyroan PWS	28	Drinking Water - Audit Monitoring - Public	14340704	18/06/2014	<0.005	<0.005	<0.5	<0.01	<10	<0.03	<1
Mountmellick PWS	104	Drinking Water - Audit Monitoring - Public	14340706	18/06/2014	<0.005	<0.005	<0.5	<0.01	<10	<0.03	<1
Portarlinton 1 PWS	91	Drinking Water - Audit Monitoring - Public	14340708	18/06/2014	<0.005	<0.005	<0.5	0.01	<10	<0.03	<1
Portlaoise PWS	140	Drinking Water - Audit Monitoring - Public	14340712	18/06/2014	<0.005	<0.005	<0.5	<0.01	<10	<0.03	<1
Arles PWS	13	Drinking Water - Audit Monitoring - Public	14340700	17/06/2014	<0.005	<0.005	<0.5	<0.01	<10	<0.03	<1
Coolanaugh PWS	4	Drinking Water - Audit Monitoring - Public	14340694	17/06/2014	<0.005	<0.005	<0.5	<0.01	<10	<0.03	<1
Graigecullen PWS	32	Drinking Water - Audit Monitoring - Public	14340696	17/06/2014	<0.005	<0.005	<0.5	<0.01	<10	<0.3	<1
South East Regional PWS	15	Drinking Water - Audit Monitoring - Public	14340770	17/06/2014	<0.005	<0.005	<0.5	<0.01	<10	<0.03	<1
Swan PWS	26	Drinking Water - Audit Monitoring - Public	14340692	17/06/2014	<0.005	<0.005	<0.5	<0.01	<10	<0.03	<1
The Strand PWS	7	Drinking Water - Audit Monitoring - Public	14340690	17/06/2014	<0.005	<0.005	<0.5	<0.01	<10	<0.03	<1

EntityName	Arsenic	Benzene	Benzo(a)pyrene	Boron	Bromate	Cadmium	Chloride	Chlorothalonil	Chlorpyrifos	Cypermethrin	Chromium	C. Perfringens	Coliform Bacteria
Units	µg/l	µg/l	µg/l	µg/l	µg/l	µg/l	mg/l	µg/l	µg/l	µg/l	µg/l	MPN/100	MPN/100
2014 DW Regs Limit (MAC)	10	1	0.01	1000	10	5	250	0.1	0.1	0.1	50	0	0
Ballinakill 1 PWS	<1	<0.5	<0.003	21	<1	<0.02	18	<0.01	<0.01	<0.01	3.5	0	0
Clonaslee PWS	<1	<0.5	<0.003	20	<1	<0.02	15	<0.01	<0.01	<0.01	1.1	0	0
Durrow 1 PWS	<1	<0.5	<0.003	32	<1	<0.02	24	<0.01	<0.01	<0.01	2.8	0	0
Rosenallis PWS	<1	<0.5	<0.003	51	<1	<0.02	25	<0.01	<0.01	<0.01	2.5	0	0
Abbeyleix 2 PWS	<1	<0.5	<0.003	43	<1	-	20	<0.01	<0.01	<0.01	3.5	0	0
Abbeyleix 1 PWS	<1	<0.5	<0.003	43	<1	<0.02	21	<0.01	<0.01	<0.01	3.5	0	0
Ballyroan PWS	<1	<0.5	<0.003	27	<1	<0.02	183	<0.01	<0.01	<0.01	<1	0	0
Mountmellick PWS	<1	<0.5	<0.003	25	<1	<0.02	20	<0.01	<0.01	<0.01	<1	0	0
Portarlinton 1 PWS	<1	<0.5	<0.003	18	<1	0.06	18	<0.01	<0.01	<0.01	<1	0	0
Portlaoise PWS	<1	<0.5	<0.003	20	<1	<0.02	26	<0.01	<0.01	<0.01	<1	0	0
Arles PWS	<1	<0.5	<0.003	18	<1	<0.02	73	<0.01	<0.01	<0.01	<1	0	0
Coolanough PWS	<1	<0.5	<0.003	12	<1	0.05	18	<0.01	<0.01	<0.01	1.1	0	0
Graigecullen PWS	<1	<0.5	<0.003	13	<1	<0.02	19	<0.01	<0.01	<0.01	<1	0	0
South East Regional PWS	<1	<0.5	<0.003	16	<1	0.06	18	<0.01	<0.01	<0.01	<1	0	0
Swan PWS	<1	<0.5	<0.003	26	<1	<0.02	13	<0.01	<0.01	<0.01	<1	0	0
The Strand PWS	<1	<0.5	<0.003	11	<1	0.06	22	<0.01	<0.01	<0.01	1	0	0

EntityName	Colony Count 22°	Colour	Conductivity @ 20°C	Copper	Cyanide	Epichlorohydrin	E. Coli	Fenpropidin	Fenpropimorph	Fluoride	Free Residual Chlorine
Units	cfu/ml	Hazen	µS/cm	µg/l	µg/l	µg/l	MPN/100ml	µg/l	µg/l	mg/l	mg/l
2014 DW Regs Limit (MAC)	no abnormality	20	2500	2000	50	0.1	0	0.1	0.1	0.8	n/a
Ballinakill 1 PWS	124	<5	652	3.3	<5	<0.05	0	<0.005	<0.005	<0.25	0.33
Clonaslee PWS	4	<5	404	4.9	<5	<0.05	0	<0.005	<0.005	0.59	0.23
Durrow 1 PWS	2	<5	641	5.8	<5	<0.05	0	<0.005	<0.005	<0.2	0.42
Rosenallis PWS	0	<5	583	14	<5	<0.05	0	<0.005	<0.005	<0.2	0.3
Abbeyleix 2 PWS	0	<5	704	8	<5	<0.05	0	<0.005	<0.005	<0.2	0.22
Abbeyleix 1 PWS	2	<5	720	5.6	14.6	<0.05	0	<0.005	<0.005	0.73	0.52
Ballyroan PWS	4	<5	661	5.4	<5	<0.05	0	<0.005	<0.005	<0.25	0.28
Mountmellick PWS	80	<5	735	91	<5	<0.05	0	<0.005	<0.005	0.71	0.44
Portarlinton 1 PWS	116	<5	713	9	<5	<0.05	0	<0.005	<0.005	0.25	0.08
Portlaoise PWS	2	<5	753	21	<5	<0.05	0	<0.005	<0.005	0.42	0.39
Arles PWS	0	<5	834	34	<5	<0.05	0	<0.005	<0.005	<0.25	0.43
Coolanough PWS	4	<5	593	12	<5	<0.05	0	<0.005	<0.005	<0.25	0.77
Graigecullen PWS	19	<5	527	9.3	<5	<0.05	0	<0.005	<0.005	0.72	0.43
South East Regional PWS	5070	<5	576	15	<5	<0.05	0	<0.005	<0.005	0.25	0.12
Swan PWS	33	<5	470	7.5	<5	<0.05	0	<0.005	<0.005	<0.25	0.22
The Strand PWS	80	<5	643	3.8	<5	<0.05	0	<0.005	<0.005	<0.25	0.2

EntityName	Glyphosate	Heptachlor	Heptachlor Epoxide	Enterococci	Epoxiconazole	Iron	Isoproturon	Lead	Lindane	Manganese	MCPA	Mecoprop	Mercury
Units	µg/l	µg/l	µg/l	MPN/100ml	µg/l	µg/l	µg/l	µg/l	µg/l	µg/l	µg/l	µg/l	µg/l
2014 DW Regs Limit (MAC)	0.1	0.03	0.03	0	0.1	200	0.1	10	0.1	50	0.1	0.1	1
Ballinakill 1 PWS	<0.01	<0.01	<0.01	0	<0.005	<10	<0.005	<1	<0.01	-	<0.01	<0.005	<0.5
Clonaslee PWS	<0.01	<0.01	<0.01	0	<0.005	<10	<0.005	<1	<0.01	-	0.02	<0.005	<0.5
Durrow 1 PWS	<0.01	<0.01	<0.01	0	<0.005	<10	<0.005	<1	<0.01	-	<0.01	<0.005	<0.5
Rosenallis PWS	<0.01	<0.01	<0.01	0	<0.005	<10	<0.005	<1	<0.01	-	<0.01	<0.005	<0.5
Abbeyleix 2 PWS	<0.01	<0.01	<0.01	0	<0.005	<10	<0.005	<1	<0.01	-	<0.01	<0.005	<0.5
Abbeyleix 1 PWS	<0.01	<0.01	<0.01	0	<0.005	<10	<0.005	<1	<0.01	-	<0.01	<0.005	<0.5
Ballyroan PWS	<0.01	<0.01	<0.01	0	<0.005	<10	<0.005	<1	<0.01	<5	<0.01	<0.005	<0.5
Mountmellick PWS	<0.01	<0.01	<0.01	0	<0.005	<10	<0.005	<1	<0.01	<5	<0.01	<0.005	<0.5
Portarlinton 1 PWS	<0.01	<0.01	<0.01	0	<0.005	<10	<0.005	<1	<0.01	8	<0.01	<0.005	<0.5
Portlaoise PWS	<0.01	<0.01	<0.01	0	<0.005	<10	<0.005	<1	<0.01	<5	<0.01	<0.005	<0.5
Arles PWS	<0.01	<0.01	<0.01	0	<0.005	14	<0.005	2	<0.01	15	<0.01	<0.005	<0.5
Coolanagh PWS	<0.01	<0.01	<0.01	0	<0.005	340	<0.005	<1	<0.01	<5	<0.01	<0.005	<0.5
Graigecullen PWS	<0.01	<0.01	<0.01	0	<0.005	<10	<0.005	<1	<0.01	<5	<0.01	<0.005	<0.5
South East Regional PWS	<0.01	<0.01	<0.01	0	<0.005	<10	<0.005	<1	<0.01	<5	<0.01	<0.005	<0.5
Swan PWS	<0.01	<0.01	<0.01	0	<0.005	<10	<0.005	<1	<0.01	<5	<0.01	<0.005	<0.5
The Strand PWS	<0.01	<0.01	<0.01	0	<0.005	<10	<0.005	<1	<0.01	1200	<0.01	<0.005	<0.5

EntityName	Nickel	Nitrate	Nitrite	PAHs	Pendimethalin	pH	Propiconazole	Selenium	Simazine	Sodium	Sulphate
Units	µg/l	mg/l	mg/l	µg/l	µg/l	-	µg/l	µg/l	µg/l	mg/l	mg/l
2014 DW Regs Limit (MAC)	20	50	0.5	0.1	0.1	6.5 to 9.5	0.1	10	0.1	200	250
Ballinakill 1 PWS	<1	23.5	<0.013	<0.01	<0.005	7.5	<0.005	<1	<0.005	-	8
Clonaslee PWS	<1	5.1	<0.013	<0.01	<0.005	7.5	<0.005	<1	<0.005	-	24
Durrow 1 PWS	<1	37.2	<0.013	<0.01	<0.005	7.8	<0.005	1.3	<0.005	-	15
Rosenallis PWS	<1	<0.89	<0.013	<0.01	<0.005	7.7	<0.005	<1	<0.005	-	19
Abbeyleix 2 PWS	1	23	<0.013	<0.01	<0.005	7.3	<0.005	<1	<0.005	-	9
Abbeyleix 1 PWS	<1	37	<0.013	<0.01	<0.005	7.3	<0.005	<1	<0.005	-	11
Ballyroan PWS	<1	25.2	<0.013	<0.01	<0.005	7.9	<0.005	<1	<0.005	7.9	16
Mountmellick PWS	<1	12.3	<0.013	<0.01	<0.005	8	<0.005	<1	<0.005	8.8	54
Portarlinton 1 PWS	1.5	1.6	<0.013	<0.01	<0.005	7.8	<0.005	<1	<0.005	9.2	32
Portlaoise PWS	<1	27.9	<0.013	<0.01	<0.005	7.9	<0.005	2.8	<0.005	180	56
Arles PWS	<1	2.4	<0.013	<0.01	<0.005	7.7	<0.005	<1	<0.005	<1	59
Coolanough PWS	<1	15.5	<0.013	<0.01	<0.005	7.6	<0.005	<1	<0.005	8.2	18
Graiguecullen PWS	<1	<0.89	<0.013	<0.01	<0.005	7.9	<0.005	<1	<0.005	10	20
South East Regional PWS	<1	18.6	<0.013	<0.01	<0.005	7.7	<0.005	<1	<0.005	7.2	11
Swan PWS	<1	<0.89	<0.013	<0.01	<0.005	7.9	<0.005	<1	<0.005	22	23
The Strand PWS	<1	1.4	<0.013	<0.01	<0.005	7.6	<0.005	<1	<0.005	12	17

EntityName	Tetrachloroethene and Trichloroethene	Total Chlorine	Total Organic Carbon	THMs	Trichlorpyr	Turbidity	Vinyl Chloride
Units	µg/l	mg/l	mg/l	µg/l	µg/l	NTU	µg/l
2014 DW Regs Limit (MAC)	10	n/a	no abnormality	100	0.1	4	0.5
Ballinakill 1 PWS	1	0.37	<1	21.5	<0.005	<0.5	<0.5
Clonaslee PWS	1	0.23	2	88.9	<0.005	<0.5	<0.5
Durrow 1 PWS	1	0.47	<1	17.1	0.01	<0.5	<0.5
Rosenallis PWS	1	0.33	<1	20.1	<0.005	<0.5	<0.5
Abbeyleix 2 PWS	1	0.32	1.5	24.7	<0.005	<0.5	<0.5
Abbeyleix 1 PWS	1	0.67	<1	11.7	<0.005	<0.5	<0.5
Ballyroan PWS	1	0.33	<1	4.2	<0.005	<0.2	<0.5
Mountmellick PWS	1	0.52	12	9.7	<0.005	<0.2	<0.5
Portarlinton 1 PWS	<0.5	0.22	1.4	10.6	<0.005	<0.2	<0.5
Portlaoise PWS	1	0.45	<1	8.6	<0.005	<0.2	<0.5
Arles PWS	1	0.48	<1	5.9	<0.005	0.5	<0.5
Coolanagh PWS	1	0.78	11.8	2	<0.005	<0.2	<0.5
Graigecullen PWS	<0.5	0.46	1	3.4	<0.005	<0.2	<0.5
South East Regional PWS	1	0.3	<1	12.8	<0.005	<0.2	<0.5
Swan PWS	1	0.31	1.6	5.9	<0.005	<0.2	<0.5
The Strand PWS	1	0.3	<1	7.5	<0.005	0.2	<0.5